

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1190283

Product: Rigid pipes with belling at one end with accessories

Type: PT32016/2(3)/S to PT32063/2(3)/S
PT75016/2(3)/S to PT75063/2(3)/S

Rating: -25°C to +60°C, 320 N and 750 N

Ordering firm: MALPRO, spol. s r.o.
Lípa 318, 763 11 Lípa, Czech Republic

Manufacturer: MALPRO, spol. s r.o.
Lípa 318, 763 11 Lípa, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 911159-01/01 of: 24.04.2019

A sample of the product was found to be in conformity with:
ČSN EN 61386 ed.2:09, ČSN EN 61386-21:04+A11:11

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 911159 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.05.2022

02.05.2019

Prague


Mgr. Miroslav Sedláček
Head of Certification Body



911159-01